

KARNATAKA ANTIBIOTICS & PHARMACEUTICALS LIMITED

(A Government of India Enterprise)

ENQUIRY REF. No.	. K-E&P/SR/0304/2024-2	
DATE	16/05/2024	
DUE DATE	22/05/2024	

Dear Sir,

Please submit your lowest and competitive offer in a SEALED ENVELOPE, DULY SUPERSCRIBING OUR ABOVE ENQUIRY REF. NO., DATE and DUE DATE on it/ OR MAIL, with other details of F.O.R terms, Taxes, Credit period, Delivery offered, Name of the Make, Detailed Specification etc., for below mentioned material/s

NO		
ITEM DESCRIPTION	UOM	QTY
FABRICATION OF NEW BASE FRAME FOR AHU BLOWER AND MOTOR	NOS	01
		FABRICATION OF NEW BASE FRAME FOR AHU

Please ensure that your offer reaches us on or before Due Date by courier OR Speed post to below office address:

M/S.KARNATAKA ANTIBIOTICS AND PHARMACEUTICALS LIMITED Plot No.37, Arka the Business Centre NTTF Main Road, Peenya Industrial Area 2nd phase, Bangalore-560058 Ph.No.080-23571590

OR you can also mail us to our email: purenp@kaplindia.com

NOTE:

- 1. PLEASE VISIT OUR SITE FOR BETTER UNDERSTANDING THE SCOPE OF WORK AND HAVE AN MOM COPY WITH KAPL TEAM BEFORE SENDING QUOTATION.
 - 2. IF YOU ARE NOT PARTICIPATING IN THE TENDER PLEASE SEND A REGRET LETTER.
 - 3. VENDOR HAS TO QUOTE AS PER BOQ ONLY IN YOUR COMPANY LETTER HEAD.
 - 4. SPECIFICATION TWO SHEET ATTACHED.

Thanking you,

Yours faithfully, For KARNATAKA ANTIBIOTICS & PHARMACEUTICALS LIMITED

YUVARAJA M

DEPUTY MANAGER PURCHASE DEPT

MOB: 9945317873

CIN: U24231KA1981GOI004145

26

No: K-E&P/NP-section

Date: 08/05/2024

REPAIR ADVICE NOTE

To: Purchase Dept.	From: E & P

Through:

Dear Sir,

Subject: Fabrication of new base frame for AHU blower and motor.

With respect to the above subject, in penicillin block AHU blower and motor base frame is completely broken and the base frame needs to be newly fabricated. Removing and mounting back of the motor and blower with proper alignment needs to be included.

For reference image is also attached.

NOTE:- Vendor has to visit the site and understand the scope of work and take measurement of the base frame before quoting.

Engg contact person: - Trishul.G Ph.no:- 9632065190



