



**KARNATAKA ANTIBIOTICS &
PHARMACEUTICALS LIMITED**

(A Government of India Enterprise)

ENQUIRY REF. No.	K-E&P/DP/SR/0702/2024-25
DATE	25.06.2024
DUE DATE	01.07.2024 till 1:00 PM

Dear Sir,

Please submit your lowest and competitive offer in a SEALED ENVELOPE, DULY SUPERSCRIBING OUR ABOVE ENQUIRY REF. NO., DATE and DUE DATE on it/ OR MAIL, with other details of F.O.R terms, Taxes, Credit period, Delivery offered, Name of the Make, Detailed Specification etc., for the below Supply or Service

SI No	Item Code	Item Description	Uom	Qty
01	---	AMC FOR PURIFIED WATER PLANT 1200 LPH INCLUDING DE-SCALING CHEMICALS, SANITIZATION WITH MINNCARE CHEMICAL FOR ONE YEAR AS PER TECHNICAL BID ENCLOSED AS ANNEXURE	NO.	01

SERVICE REQUIRED AT OUR AYUSH PLANT, DHARWAD

Please ensure that your offer reaches us on or before Due Date by courier OR Speed post to below office address:

M/s. Karnataka Antibiotics and Pharmaceuticals Limited
Plot No.37, Arka The Business Centre
NTTF Main Road, Peenya Industrial Area
2nd Phase, Bengaluru-560058
Ph. No.080-23571590

OR you can also mail us to our email: puren@kaplindia.com

NOTE:

- PLEASE VISIT OUR SITE FOR BETTER UNDERSTANDING THE SCOPE OF WORK
- IF YOU ARE NOT PARTICIPATING IN THE TENDER PLEASE SEND A REGRET LETTER.
- VENDOR HAS TO QUOTE AS PER OUR TENDER BOQ ONLY IN YOUR COMPANY LETTER HEAD.

Thanking you,

Yours faithfully,
For KARNATAKA ANTIBIOTICS
& PHARMACEUTICALS LIMITED

YUVARAJA. M
DY. MANAGER – PURCHASE DEPT.
MOB: 9945317873

Karnataka Antibiotics and Pharmaceuticals Limited,

Ayush Plant- Dharwad

PR No. 2025D00010

Date: 15.05.2024

Technical Bid

Subject: AMC service for Purified water plant 1200 LPH including De - scaling chemicals, sanitization with Minncare chemical for one year.

No of visits: 2 months once service visit include one Annual service visit Total 6 Service visit and unlimited Breakdown calls.

Job Description:

2 MONTHS ONCE SERVICE VISIT:-

1. Checking the overall performance of WTP and thoroughly checking the log sheets
2. Improving the performance by mild cleaning (de-scaling) or any other related service activity
3. All mechanical failure will be attended if required
4. Checking chemical dosage rate across the scheme
5. Changing interconnectors, O rings, end cap O rings etc if required
6. Membrane sterilization with Minncare Chemical and testing with minncare strip for zero residual
7. Cleaning of RO and Purified Storage tank
8. Regeneration of water treatment plant

ANNUAL SERVICE VISIT:-

1. Improving the performance by suggesting operational guidelines
2. Profiling of pressure tubes and understand the performance of individual membranes and cleaning activity will be performed if required
3. Changing of filter media for MGF
4. Changing inter connectors, O rings, brine seals, end cap O rings of RO plant
5. Servicing of process on-line instruments.
6. Overhauling of differing stages of water processing plant

AMC TERMS AND CONDITIONS

- All cleaning and sanitization chemical to be provided by vender **except regeneration chemicals, daily dosing chemicals like antiscalant chemicals, chlorination, de chlorination chemicals and any water plant spares will not come under vendor scope. And will provided by KAPL**
- Cleaning chemical- Citric aci, Qty appx 30-40 kg
Amino bi fluoride, Qty appx 20- 30 kg
- Sanitization chemical - Minncare , Qty appx- 15- 20 ltr

- Chemicals MSDS to be given
- SOP of sanitaisation to be given
- Safety measure to be taken during service
- Only experience engineers/technicians/mechanics helpers, whose character and antecedents have already been verified, will be deputed to attend the work.
- There should be adequate number of Telephone lines for lodging of service requests. If the AMC Provider firm failed to attend the calls within 24 hours, KAPL reserves the right to get the work done by other firms and deduct such expenses from the AMC charges. In the Case of exceptional and repeated delays, poor services, fault, break down, etc, this office reserves the right to deduct such costs as deemed to be necessary by way of damages and may also cancel the AMC unilaterally.
- Service report and check list shall be given by vendor after completion each service
- PM visit schedule to be shared by vendor for 1 year and if any changes in date or reschedule will be inform to vendor in 2 days advance.
- Servicing of any Mechanical breakdown work of water system plant to be covered under AMC. For Any spares required for rectification of break down will provided by KAPL
- Electrical maintenance service and instruments calibration not included in AMC

List of Equipment cover under AMC

MGF	Cation	Anion
Softer	Mixed Bed	UV system
RO plant	Dosing Pumps 3nos	Feed pumps 4 nos

Above terms and conditions are agreed

Company name

Name:

Seal and Signature: