



**KARNATAKA ANTIBIOTICS &
PHARMACEUTICALS LIMITED**

(A Government of India Enterprise)

ENQUIRY REF. No.	K-E&P/SR/DP/1132/2024-25
DATE	19.08.2024
DUE DATE	26.08.2024 till 1:00 PM

Dear Sir,

Please submit your lowest and competitive offer in a SEALED ENVELOPE, DULY SUPERSCRIBING OUR ABOVE ENQUIRY REF. NO., DATE and DUE DATE on it. Mentioned other details of F.O.R terms, Taxes, Credit period, Delivery offered, Name of the Make, Detailed Specification etc., for the below Supply or Service

SI No	Item Code	Item Description	Uom	Qty
01	MGW2274	AMC FOR SPLIT AIR CONDITIONERS FOR 2 YEARS AS PER TECHNICAL BID ENCLOSED	NO.	01

SERVICE REQUIRED AT OUR AYUSH PLANT, DHARWAD

Please ensure that your offer reaches us on or before Due Date by courier OR Speed post or by Hand in sealed cover only to below office address:

*M/s. Karnataka Antibiotics and Pharmaceuticals Limited
Plot No.37, Arka The Business Centre,NTTF Main Road, Peenya Industrial Area
2nd Phase, Bengaluru-560058 Ph. No.080-23571590*

NOTE:

01. PLEASE VISIT OUR SITE FOR BETTER UNDERSTANDING THE SCOPE OF WORK
02. IF YOU ARE NOT PARTICIPATING IN THE TENDER PLEASE SEND A REGRET LETTER.
03. VENDOR HAS TO QUOTE AS PER OUR TENDER IN YOUR COMPANY LETTER HEAD.
04. QUOTATION MUST BE SUBMITTED IN TWO SEALED COVERS (TECHNICAL & COMMERCIAL BID) SEPARATELY AND IN ONE ENVELOPE OR ELSE YOUR PROPOSAL WILL NOT BE CONSIDERED.

IF YOU NEED ANY CLARIFICATION, PLEASE CONTACT US.

Thanking you,

Yours faithfully,
For KARNATAKA ANTIBIOTICS
& PHARMACEUTICALS LIMITED


YUVARAJA. M
DY. MANAGER – PURCHASE DEPT.
MOB: 9945317873

KARNATAKA ANTIBIOTICS AND PHARMACEUTICALS LTD
AYUSH PLANT DHARWAD -580011.

PR No. 2023D00030

Date: 01.07.2024

Technical Bid

Sub: COMPREHENSIVE AMC FOR SPLIT AIR CONDITIONERS AT KAPL AYUSH PLANT DHARWAD.

Visits: Total 6 Preventive maintenance visits, once in two months service in a year and unlimited break down call service.

Note: Before quoting, please visit the site and refer capacity, make, condition of AC and other details.

Validity AMC: 2 years from date of Work order

AMC TERMS AND CONDITIONS

I. Preventive Maintenance: - A service technician shall visit the KAPL -Dharwad site Once-In-Two months to monitor the health of the equipment.

Preventive maintenance of air AC following parameters to be checked

- Clean Air Filter.
- Clean evaporator and condenser coils
- Inspect and clean drain line.
- Lubricate blower and condenser fans.
- Inspect electrical wirings and controls.
- Check thermostat for proper operation.
- Check the PCB board
- Checking of cold insulation

II. Break-Down Services: - Any breakdown call reported by customer within a short time or not more than 24 hrs to ensure the maximum available time of equipment for use.

All Electrical & Mechanical breakdown / Preventive maintenance to be cover under AMC

All material of air conditioners cover under AMC including compressor, indoor and outdoor fan motor, Fan blade of indoor and outdoor unit, evaporator coil, condenser coil, Gas charging, gas leakage arrest, PCB board, contactors, capacitors, relay, starting component, cold insulation AC remote.. Etc

PM visit schedule to be shared by vendor for 1 year and if any changes in date or reschedule will be inform to vendor in 2 days advance.

If the faulty component is not repairable, the vendor has to replace the item with the same specification and make. The replaced item shall remain as KAPL property.

Any material taken for repair should be returned back within 7 working days.

Equipment is taken out for repair vendor shall provide stand by with the same configuration.

There should be adequate number of telephone lines for lodging of service requests. If the AMC Provider firm failed to attend the calls within 24 hours, KAPL reserves the right to get the work done by other firms and deduct such expenses from the AMC charges. In the Case of exceptional and repeated delays, poor services, fault, break down, etc, this office reserves the right to deduct such costs as deemed to be necessary by way of damages and may also cancel the AMC unilaterally.

Service report and check list shall be given by vendor after completion each service

Details of Air Conditioners to be covered under AMC along with the location of installation are given below.





List of air conditioners			
Sl. No.	AC location	Capacity in TR	Make
1	Conference room	1.5	VOLTAS split AC
2	Server ROOM	1	VOLTAS split AC
3	QC control sample area	2	Blue star inverter split AC
4	QC control sample area	2	Blue star inverter split AC
5	QC instruments Lab	2	Blue star inverter split AC
6	QC LAF area	1.5	Blue star inverter split AC
7	Stores dept. dispensing area	2	Blue star inverter split AC
8	Stores dept. heavy metal store room	2	Blue star inverter split AC
9	Chemical store room	2	VOLTAS Window AC

Above terms and conditions are agreed

Name:

Seal and Signature:

Company name

Preparer By	Checked By		Approved By
 01/07/2024	 01/07/2024	 01/07/2024	
JE(SRS)	AM(BSL)	SM(NG)	GM(SK)