



**KARNATAKA ANTIBIOTICS &
PHARMACEUTICALS LIMITED**

(A Government of India Enterprise)

ENQUIRY REF. No.	K-E&P/SR/1271/2024-25
DATE	05.09.2024
DUE DATE	12.09.2024 till 1:00 PM

Dear Sir,

Please submit your lowest and competitive offer in a SEALED ENVELOPE, DULY SUPERSCRIBING OUR ABOVE ENQUIRY REF. NO., DATE and DUE DATE on it. Mentioned other details of F.O.R terms, Taxes, Credit period, Delivery offered, Name of the Make, Detailed Specification etc., for the below Supply or Service

Sl No	Item Code	Item Description	Uom	Qty
01	----	REPLACEMENT OF VACUUM INTERRUPTERS FOR VCB'S IN HT PANEL AT KAPL FACTORY AS PER DETAILS ENCLOSED AS ANNEXURE	No.	01

Please ensure that your offer reaches us on or before Due Date by courier OR Speed post or by Hand in sealed cover only to below office address:

M/s. Karnataka Antibiotics and Pharmaceuticals Limited
Plot No.37, Arka The Business Centre, NTTF Main Road, Peenya Industrial Area
2nd Phase, Bengaluru-560058 Ph. No.080-23571590

NOTE:

01. PLEASE VISIT OUR SITE FOR BETTER UNDERSTANDING THE SCOPE OF WORK
02. IF YOU ARE NOT PARTICIPATING IN THE TENDER PLEASE SEND A REGRET LETTER.
03. VENDOR HAS TO QUOTE AS PER OUR TENDER IN YOUR COMPANY LETTER HEAD.
04. QUOTATION MUST BE SUBMITTED IN TWO SEALED COVERS (TECHNICAL & COMMERCIAL BID) SEPARATELY AND IN ONE ENVELOPE OR ELSE YOUR PROPOSAL WILL NOT BE CONSIDERED.

IF YOU NEED ANY CLARIFICATION, PLEASE CONTACT US.

Thanking you,

Yours faithfully,
For KARNATAKA ANTIBIOTICS
& PHARMACEUTICALS LIMITED

YUVARAJA. M
DY. MANAGER – PURCHASE DEPT.
MOB: 9945317873

KARNATAKA ANTIBIOTICS AND PHARMACEUTICALS LIMITED, PEENYA.

BOQ FOR REPLACEMENT OF VACUUM INTERRUPTERS FOR VCBs

SPARES AND SERVICING OF 3 Nos of VCBs at HT Panel

SL NO	DESCRIPTION	QTY	RATE	AMOUNT
1	Supply of New Vacuum Interrupter for 11 KV, 1250A ABB Make VCB at HT Panel (for 3 nos of VCBs). Model:- Vmax 12.12.25	09 Nos.		
2	Removing of existing vacuum interrupters from all 11 KV VCBs and fixing of new Vacuum Interrupters. The breaker testing to be done for all 3 VCBs including control circuits and report to be submitted.	03 Nos.		
3	Breaker control rotary Switch need to be checked and resolved for it's operation (In Trip position it is working, but in closing position is not working).	2 Nos.		

Terms & Condition:-

1. All supporting tools (electrical/mechanical) and safety precautions to be taken care from the vendor side during the work.
2. The vendor has to visit the site, for any clarifications in order to understand the scope of work.
3. After completing the work, the vendor has to hand over the HT panel in working and smooth operation condition.
4. ESI & other statutory requirements are mandatory.
5. Warranty for the spares should be given for 'ONE' year.

T-JE(RAV)
11/07/24

E(SCI)

DM(SKS)

000
DM(MKM)

SM(SRD)
11/07/2024

DGM(KDP)
12/21/24